

Statement of Conformity

Floor coverings- Determination of the anti-slip properties

Statement no.: **7982044**

Name and address
of the manufacturer: **ACCIAI SPECIALI TERNI S.p.A.**
Viale B. Brin, 218
I-05100 Terni (TR)
ITALY

We hereby state, that the mentioned below product has been tested in accordance with the test methods specified in the technical specification, confirming its intended use in working areas with slipping hazards.
Evaluation group of slip resistance: R12
Evaluation group of displacement volume: V10

Tested according to: **DIN EN 16165:2021-12 annex B**
ASR A1.5 / 1.2 Edition: March 2022
DIN 51133: 2021-12

Test report no.: **2022 22897/3210 IFA test report**
dated 07/11/2022

Description of product /
Type designation: **Pickled stainless steel tear plate type**
"MANDORLATO" according to ASTM A240 / A793 /
EN10088/1 and 2: AISI 304 or AISI 316 L

Manufacturing plant: **ACCIAI SPECIALI TERNI S.p.A.**
Viale B. Brin, 218
I-05100 Terni (TR)
ITALY

Valid until: **November 6, 2027**

Pogliano Mil.se , 07/11/2022

TÜV Rheinland Italia S.r.l.
Via Mattei, 3 - 20005 Pogliano Milanese (MI)
ITALY

Lorenzo Antonello
Industrial Services



 **TÜVRheinland®**
Precisely Right.