

Energy performance certificate (EPC)

Apartment 507 Torrens Apartments
Waterman Walk
SALFORD
M50 3AS

Energy rating

B

Valid until: **5 December 2028**

Certificate number: **0548-0981-7382-5878-7934**

Property type

Mid-floor flat

Total floor area

65 square metres

Rules on letting this property

Properties can be rented if they have an energy rating from A to E.

If the property is rated F or G, it cannot be let, unless an exemption has been registered. You can read [guidance for landlords on the regulations and exemptions \(https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance\)](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

Energy efficiency rating for this property

This property's current energy rating is B. It has the potential to be B.

[See how to improve this property's energy performance.](#)

| Score | Energy rating | Current | Potential |
|-------|---------------|---------------|---------------|
| 92+ | A | | |
| 81-91 | B | 85 B | 85 B |
| 69-80 | C | | |
| 55-68 | D | | |
| 39-54 | E | | |
| 21-38 | F | | |
| 1-20 | G | | |

The graph shows this property's current and potential energy efficiency.

Properties are given a rating from A (most efficient) to G (least efficient).

Properties are also given a score. The higher the number the lower your fuel bills are likely to be.

For properties in England and Wales:

the average energy rating is D
the average energy score is 60

Breakdown of property's energy performance

This section shows the energy performance for features of this property. The assessment does not consider the condition of a feature and how well it is working.

Each feature is assessed as one of the following:

- very good (most efficient)
- good
- average
- poor
- very poor (least efficient)

When the description says "assumed", it means that the feature could not be inspected and an assumption has been made based on the property's age and type.

| Feature | Description | Rating |
|----------------------|---|-----------|
| Walls | Average thermal transmittance 0.26 W/m ² K | Very good |
| Windows | High performance glazing | Very good |
| Main heating | Room heaters, electric | Very poor |
| Main heating control | Programmer and appliance thermostats | Good |
| Hot water | Electric immersion, standard tariff | Very poor |
| Lighting | Low energy lighting in all fixed outlets | Very good |
| Air tightness | Air permeability 1.7 m ³ /h.m ² (as tested) | Very good |
| Roof | (other premises above) | N/A |
| Floor | (other premises below) | N/A |
| Secondary heating | None | N/A |

Primary energy use

The primary energy use for this property per year is 102 kilowatt hours per square metre (kWh/m²).

Environmental impact of this property

This property's current environmental impact rating is B. It has the potential to be B.

Properties are rated in a scale from A to G based on how much carbon dioxide (CO₂) they produce.

Properties with an A rating produce less CO₂ than G rated properties.

An average household produces 6 tonnes of CO₂

This property produces 1.1 tonnes of CO₂

This property's potential production 1.1 tonnes of CO₂

By making the [recommended changes](#), you could reduce this property's CO₂ emissions by 0.0 tonnes per year. This will help to protect the environment.

Environmental impact ratings are based on assumptions about average occupancy and energy use. They may not reflect how energy is consumed by the people living at the property.

How to improve this property's energy performance

The assessor did not make any recommendations for this property.

[Simple Energy Advice has guidance on improving a property's energy use.](https://www.simpleenergyadvice.org.uk/)
(<https://www.simpleenergyadvice.org.uk/>)

Paying for energy improvements

[Find energy grants and ways to save energy in your home.](https://www.gov.uk/improve-energy-efficiency) (<https://www.gov.uk/improve-energy-efficiency>)

Estimated energy use and potential savings

| | |
|--|------|
| Estimated yearly energy cost for this property | £358 |
|--|------|

| | |
|------------------|----|
| Potential saving | £0 |
|------------------|----|

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is not based on how energy is used by the people living at the property.

The estimated saving is based on making all of the recommendations in [how to improve this property's energy performance](#).

For advice on how to reduce your energy bills visit [Simple Energy Advice](#) (<https://www.simpleenergyadvice.org.uk/>).

Heating use in this property

Heating a property usually makes up the majority of energy costs.

Estimated energy used to heat this property

| | |
|---------------|-----------------|
| Space heating | 82 kWh per year |
|---------------|-----------------|

| | |
|---------------|-------------------|
| Water heating | 1618 kWh per year |
|---------------|-------------------|

Potential energy savings by installing insulation

The assessor did not find any opportunities to save energy by installing insulation in this property.

You might be able to receive [Renewable Heat Incentive payments](#) (<https://www.gov.uk/domestic-renewable-heat-incentive>). This will help to reduce carbon emissions by replacing your existing heating system with one that generates renewable heat. The estimated energy required for space and water heating will form the basis of the payments.

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

| | |
|-----------------|--|
| Assessor's name | Paul Byrne |
| Telephone | 01516 916 685 |
| Email | paul.byrne@pbsustainability.co.uk |

Accreditation scheme contact details

| | |
|----------------------|--|
| Accreditation scheme | Stroma Certification Ltd |
| Assessor ID | STRO011431 |
| Telephone | 0330 124 9660 |
| Email | certification@stroma.com |

Assessment details

| | |
|------------------------|---------------------|
| Assessor's declaration | No related party |
| Date of assessment | 4 December 2018 |
| Date of certificate | 6 December 2018 |
| Type of assessment | SAP |
