

**BETA** This is a new service – your [feedback](#) will help us to improve it.

[< Back](#)

# Energy performance certificate (EPC)

## Certificate contents

- [Rules on letting this property](#)
- [Energy performance rating for this property](#)
- [Breakdown of property’s energy performance](#)
- [Environmental impact of this property](#)
- [How to improve this property’s energy performance](#)
- [Estimated energy use and potential savings](#)
- [Contacting the assessor and accreditation scheme](#)

602 Block B 215 Chapel Street 215 Chapel Street SALFORD M3 5PE		Energy rating  <b>B</b>
<b>Valid until 25 September 2030</b>	Certificate number <b>2843-5017-3301-2940-7264</b>	

[Print this certificate](#)

<b>Property type</b>	Mid-floor flat
<b>Total floor area</b>	62 square metres

## Rules on letting this property

Properties can be rented if they have an energy rating from A to E.

If the property is rated F or G, it cannot be let, unless an exemption has been registered. You can read [guidance for landlords on the regulations and exemptions](#).

## Energy efficiency rating for this property

This property’s current energy rating is B. It has the potential to be B.

[See how to improve this property’s energy performance.](#)

Score	Energy rating	Current	Potential
92+	A		
81-91	B	83   B	83   B
69-80	C		
55-68	D		
39-54	E		
21-38	F		

The graph shows this property's current and potential energy efficiency.

Properties are given a rating from A (most efficient) to G (least efficient).

Properties are also given a score. The higher this number, the lower your carbon dioxide (CO<sub>2</sub>) emissions are likely to be.

The average energy rating and score for a property in England and Wales are D (60).

## Breakdown of property's energy performance

This section shows the energy performance for features of this property. The assessment does not consider the condition of a feature and how well it is working.

Each feature is assessed as one of the following:

- very good (most efficient)
- good
- average
- poor
- very poor (least efficient)

When the description says 'assumed', it means that the feature could not be inspected and an assumption has been made based on the property's age and type.

Feature	Description	Rating
Walls	Average thermal transmittance 0.17 W/m <sup>2</sup> K	Very good
Windows	High performance glazing	Very good
Main heating	Room heaters, electric	Very poor
Main heating control	Programmer and appliance thermostats	Good
Hot water	Electric immersion, standard tariff	Very poor
Lighting	Low energy lighting in all fixed outlets	Very good
Air tightness	Air permeability 2.1 m <sup>3</sup> /h.m <sup>2</sup> (as tested)	Very good
Roof	(other premises above)	N/A
Floor	(other premises below)	N/A
Secondary heating	None	N/A

### Primary energy use

The primary energy use for this property per year is 112 kilowatt hours per square metre (kWh/m<sup>2</sup>).

---

## Environmental impact of this property

One of the biggest contributors to climate change is carbon dioxide (CO<sub>2</sub>). The energy used for heating, lighting and power in our homes produces over a quarter of the UK's CO<sub>2</sub> emissions.

<b>An average household produces</b>	6 tonnes of CO <sub>2</sub>
<b>This property produces</b>	1.2 tonnes of CO <sub>2</sub>
<b>This property's potential production</b>	1.2 tonnes of CO <sub>2</sub>

By making the [recommended changes](#), you could reduce this property's CO<sub>2</sub> emissions by 0.0 tonnes per year. This will help to protect the environment.


Environmental impact ratings are based on assumptions about average occupancy and energy use. They may not reflect how energy is consumed by the people living at the property.

---

## How to improve this property's energy performance

The assessor did not make any recommendations for this property.

[Simple Energy Advice has guidance on improving a property's energy use.](#)



---

### Paying for energy improvements

[Find energy grants and ways to save energy in your home.](#)

---

## Estimated energy use and potential savings

<b>Estimated yearly energy cost for this property</b>	£423
<b>Potential saving</b>	£0

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is not based on how energy is used by the people living at the property.

The estimated saving is based on making all of the recommendations in [how](#)

[to improve this property's energy performance.](#)

For advice on how to reduce your energy bills visit [Simple Energy Advice](#).

## Heating use in this property

Heating a property usually makes up the majority of energy costs.

### Estimated energy used to heat this property

<b>Space heating</b>	267.0 kWh per year
<b>Water heating</b>	1610.0 kWh per year

### Potential energy savings by installing insulation

The assessor did not find any opportunities to save energy by installing insulation in this property.

You might be able to receive [Renewable Heat Incentive payments](#). This will help to reduce carbon emissions by replacing your existing heating system with one that generates renewable heat. The estimated energy required for space and water heating will form the basis of the payments.

---

## Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

### Assessor contact details

<b>Assessor's name</b>	Paul Byrne
<b>Telephone</b>	01516 916 685
<b>Email</b>	<a href="mailto:paul.byrne@pbsustainability.co.uk">paul.byrne@pbsustainability.co.uk</a>

### Accreditation scheme contact details

<b>Accreditation scheme</b>	Stroma Certification Ltd
<b>Assessor ID</b>	STRO011431
<b>Telephone</b>	0330 124 9660
<b>Email</b>	<a href="mailto:certification@stroma.com">certification@stroma.com</a>

### Assessment details

<b>Assessor's declaration</b>	No related party
-------------------------------	------------------

Date of assessment	24 September 2020
Date of certificate	25 September 2020
Type of assessment	▶ <a href="#">SAP</a>

---

## Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at [mhclg.digital-services@communities.gov.uk](mailto:mhclg.digital-services@communities.gov.uk), or call our helpdesk on 020 3829 0748.

There are no related certificates for this property.

---

[Accessibility statement](#)

**OGI** All content is available under the [Open Government Licence v3.0](#), except where otherwise stated



© Crown copyright