



**smart
vatten®**

VERTO

**VERTOLUMI HVAC DESIGN
GUIDELINES**

2026

1 VERTO HVAC DESIGN GUIDELINES

1.1 Space-specific water metering

The Verto system, a wireless system for metering hot and cold domestic water, is installed according to the HVAC and electrical designs. The system comprises of

- space-specific meters
- meter units and unit displays (display is optional)
- a remotely readable collection unit.

Meters (1–4 meters/ meter unit) are installed in each space, and meter units are installed near the meters. The meter units are numbered at the factory in accordance with the space numbering on the site.

The same meter (V-15UD) works on both hot and cold water lines.

The Verto objects are in the MagiCad product database.

1.2 Placement of meters, hot and cold water

The connectors are included in the delivery of the meter.

1. Install the meters into a horizontal or vertical pipe paying attention to the flow direction indication arrow on the meter body.
2. Place the meters so that they are easy to service. Make sure that their installation must meet the regulations for fire safety and electrical installations.
3. If you place the devices inside a casing or suspended ceiling, install a service hatch measuring at least 500 x 500 mm in the location of the devices.
4. We do not recommend installing the devices in the footings of kitchen cupboards or other cramped spaces. The cabinets under the kitchen sink must be waterproofed in case of possible leaks.

1.3 Basic connections of the equipment

The water pipes should be designed so that each space is only connected to the water network at one point. The circulation of hot water should be designed so that it ends before the meter.

The pipe system from the meter to the usage sites should be designed to minimize the waiting time for hot water.

1.3.1 Hot water circulation

The circulation of hot water can in some cases make water metering more difficult. The Verto system enables two or three hot water meters to be connected to the same meter unit in order to reduce the waiting time for hot water.

In such cases, the meter unit automatically calculates the readings from all of the meters belonging to the same space. Cold water can usually be metered with just one meter.

1.3.2 Two risers

When water enters via two different routes, four meters are required.

The meter unit is powered by a battery or 230V electrical power.

1.4 Naming the meter units

1. Name the meter units according to the space numbers on site (e.g. A01, A02, A03, B04, B05, etc.).
2. Provide Smartvatten with the space numbers when placing the order.

1.5 Installing the unit display

1.5.1 Installing the unit display EVN-RB

1. Remove the battery pull tab before first use.
2. Place the unit display in a dry space using the wall mount that is included in the delivery.
3. Install the wall mount in the entryway or hallway. The recommended installation height is 160 cm.
4. The unit display also features temperature and humidity measuring. Take this into account when determining the installation location.
5. The unit display and the meter unit are usually delivered pre-paired, and they must be installed in the space indicated on the casing label. Otherwise, inform Smartvatten of the serial number of the unit display. For the EVN-RB unit display, the pairing is done in the cloud service.
6. Install the unit display to the wall mount.



EVN-RB

1.5.2 Installing the unit display EVN-RC

1. Place the unit display in a dry space using the wall mount that is included in the delivery.
2. Install the wall mount in the entryway or hallway. The recommended installation height is 160 cm.
3. The unit display also features temperature and humidity measuring. Take this into account when determining the installation location.
4. The unit display and the meter unit are usually delivered pre-paired, and they must be installed in the space indicated on the casing label. Otherwise, inform Smartvatten of the serial number of the unit display. For the EVN-RC unit display, the pairing is done in the cloud service.
5. Connect the EVN-RC unit display to the 5–12 V DC power supply with a USB-C connector.
 1. For surface mounting, you can separately order the white, plug-mounted power adapter WU00064, and a 2 m long USB-C cable.
 2. For box mounting, you can separately order the power adapter WU00062, which comes with a grommet and strain relief.



More detailed electrical design instructions and examples can be found on our home pages.

3. Measure the length of the cord as shown in the figure.



4. Fasten the strain relief and the grommet of the power adapter firmly on the back of the wall mount.



6. Install the unit display to the wall mount.



EVN-RC

1.6 The collection unit and the property's main water meters

The metering data is transmitted securely from the collection unit to the Smartvatten platform cloud service by means of mobile network or a broadband connection.

1. Connect 1–4 main water meters equipped with impulse transmitters to the collection unit. As cabling, use a shielded twisted pair cable.

These water meters must be located in the same building with the collection unit.

2. Do not install weak current cables and strong current cables side by side.
3. To avoid impurities that could adversely affect water metering, install a water filter of the same size as the pipe inside the building's water supply pipes.

smart vatten®

Customer Support

Tel. 020 741 4020 | verto@smartvatten.fi



SMARTVATTEN OY 2579363-3 | FI25793633

Tel. 020 741 4020 | info@smartvatten.com
Keilaranta 10, 02150 Espoo