



SEAPA 2026 Replacement of Two Wooden Transmission Towers Project

ADDENDUM NO. 2

Date: March 2, 2026
Bids Due: March 9, 2026 @ 4:00 p.m. AKDT (no change)
Pages: One (1) total: One page of this Addendum No. 2

- Notes:**
1. Bidders must acknowledge receipt of addenda in Section 7 of the Contractor's Bid and Addendum Acknowledgment Form (Attachment 2 to the Request for Proposals).
 2. This addendum provides additional and/or modified information to the Project RFP and associated documents. This addendum forms a part of the Contract Documents. This addendum is being transmitted by e-mail to all bidders and posted on SEAPA's website at <https://www.seapahydro.org/opportunities/bids-projects>
 3. No hard copy will be sent.
 4. All other terms and conditions of the original RFP and associated documents are unchanged.
-

INQUIRY AND CLARIFICATION, AND MODIFICATION:

1. The RFP calls for both structures to be replaced. Is this correct? Will all three poles on Structure 195 be replaced?

SEAPA Response:

On Structure #194 both poles shall be replaced. On Structure #195 only one (1) pole shall be replaced as more accurately described on page 8 of the RFP as follows:

Structure 195:

Structure #195 is a unique "Tall Ship" angled H-type wooden three-pole tower. It is made up of three 80' H-1 class wooden poles. Poles are set in tall cross-braced steel pole shoes mounted on micropile. The upper portion of the structure is supported using steel cross arms and a system of guy wires for structural integrity.

One of the poles has rot and structural concerns and needs to be replaced. It will be the Head-On right-side pole on the outside of the structure at the vertex of the line angle. This will be the one furthest from the Shelter Cove Road. Owner will provide pole, hardware, and the required specialty pole clamp for attaching the new pole to existing pole shoes. Cross arms and insulators are to be reused. (Emphasis added.)

To navigate to the work sites see the ***Pole Locations and Maps*** sections above on pages 5 - 7 of this RFP.

Structure #195 is approximately 400 feet from the edge of the Shelter Cove Road. (See attached **Exhibit G** Photos.) Removal of the old **poles** and setting of new **ones** will require the services of the Owner-provided heavy lift helicopter. (Emphasis added.)

However, the last sentence of the last paragraph above that states: "Removal of the old poles and setting of the new ones will require the services of the Owner-provided heavy lift helicopter" is modified to remove the letter "s" pluralizing the number of poles as follows:

Removal of the old pole and setting of the new one will require the services of the Owner-provided heavy lift helicopter. (Emphasis added.)

End of Addendum No. 2
