

TESTING LABORATORY	No. 2017-281171221 (EN)	Date of Edition 2018-01-19	Page 1 / 1
--------------------	----------------------------	-------------------------------	---------------

Applicant IBOTEC – Industria de Tubagens, S.A. Apartado 2037 3701-906 CESAR	Date of Entry 2017-12-21
---	------------------------------------

Appliance / Product Tested	No. of Samples
Designation : Pliable conduits	Ø16. Ø50 : 12 m
Manufacturer/Trademark..... : IBOTEC	Ø20. Ø40 : 9 m
Reference..... : One Shoe 16 - 50	Ø25. Ø32 : 6 m
Ratings : Ø16 – 50 mm, 2321	
Observations : Classification: 232122670010	

Manufacturer / Representative IBOTEC – Industria de Tubagens, S.A. Apartado 2037 3701-906 CESAR

Standards / Reference Documents EN 61386-1:2008 EN 61386-22: 2004 + A11: 2010	
--	---

Type / Scope of Test Tests to check compliance with the requirements of the referenced standards.

Test Result The tested sample is in compliance with the standards requirements. The test results are described in test register no. 17-281171221. Note: the sample was tested according to the OSM/IN 227 document.
--

Test Performed by  Eduarda Gonçalves (Laboratory Technician)	Approved by  João Lopes (Technical Director)
Date 2018-01-19	Date 2018-01-19