

Troffer Mounting Instructions

IMPORTANT SAFETY INFORMATION

Please read all the instructions below before installation.

- Make sure that the supply voltage corresponds to the rated product voltage.
- The product must be installed by a qualified electrician in accordance with the National Electrical Code and corresponding codes.
- If the product is damaged, do not use it.
- The product is designed for indoor use only.



Warning: PLEASE READ AND UNDERSTAND THIS ENTIRE MANUAL BEFORE ATTEMPTING TO ASSEMBLE, OPERATE OR INSTALL THE PRODUCT.

RISK OF PERSONAL INJURY - READ and follow all WARNINGS and installation instructions.
Keep or give to the owner for future reference.

RISK OF CUTS: Wear gloves to prevent cuts or abrasions when removing from carton, handling and maintaining this product.

RISK OF ELECTRIC SHOCK: This product must be installed in accordance with the applicable installation code by a person familiar with the construction and operation of the product and the hazards involved.

RISK OF FIRE: Minimum 194°F supply conductors. Consult a qualified electrician to ensure correct branch circuit conductor.

ASD® assumes no responsibility for claims arising out of improper or careless installation or handling of this product. For recessed installation: Access above ceiling required. Inherently protected. Vapor barrier must be suitable for 194°F.

RECESSED MOUNT:

1. Remove junction box cover by removing screws to access wiring connections. Connect input conduit to junction box. Make wiring connections per electrical connections section.
2. Push all wires back into the junction box and reinstall junction box cover.
3. Hooks on the back of the panel can be used to secure the fixture in the ceiling.

