


Installation Instructions for Emergency Remote Head

Model No.: LED-EM-RC-2		
Part	Description	Quantity
1	LED remote head	1




IMPORTANT SAFEGUARDS READ AND FOLLOW ALL SAFETY INSTRUCTIONS

1. Review the diagrams thoroughly before beginning.
2. All electrical connections must be in accordance with local codes, ordinances and the National Electric code.
3. Disconnect power at fuse or circuit breaker before installing or servicing.
4. Do not mount in hazardous locations, or near gas or electric heaters.
5. Do not let power cords touch hot surface.
6. Equipment should be mounted in locations and at heights where it will not be subjected to tampering by unauthorized personnel.
7. The use of accessory equipment not recommend by the manufacturer may cause an unsafe condition.
8. Do not use this equipment for other than intended use.
9. All servicing should be performed by qualified personnel only.

ELECTRICAL CONNECTIONS

1. Connect the wires to proper power supply and place on the wall with screws.
2. The max mounting height is 7.6ft.



The max mounting height is 7.5ft.

