

# **Constant Voltage Triac Dimmable Transformers**



2.76"(70mm)	©			
	6.97*(177mm)	1.39°(36.2mm)	— 6.50"(165mm) — — — — — — — — — — — — — — — — — —	

## Project: \_\_\_\_\_ Part #: \_\_\_\_\_

### **Magnetic & Electronic Transformers**








### Features:

- · Constant Voltage Mode
- Unversal AC input / Full range: AC120-277V
- Strong Compatibility, flicker-free dimming
- ETL certification, Class II power unit
- Protections: Short circuit / Overloa d/ Over Voltage
- Fully isolated aluminum case with IP20 level
- · Suitable for dry or damp location
- Suitable for LED strip, LED modules or LED sign applications etc.

Certificates	ETL			
Protection	Short Current	Hiccup mode,recover automatically affer fault condition is removed		
	Over Loading	≤120%		
	Working TEMP.	-13°F to 113°F		
Environment	Working Humidity	20~90% RH, Non-Condensing		
	Storage TEMP. Humidity	-40~140°F, 10~95% RH		
	Safety Standards	UL8750		
Safety & EMC	Withstand Voltage	I/P-O/P: 1500VAC		
	Isolation Resistance	I/P-O/P: 100M Ω /500VDC/77*F/70% RH		
Notes	All parameters if NOT specially mentioned are measured at 120VAC input, rated load and 77°F of ambient temperature     To extend the driver's using life, please reduce the loading at lower input voltage     Loading should be 5-100%			





### Features:

- · Constant Voltage Mode
- Unversal AC input / Full range: AC120-277V
- · Strong Compatibility, flicker-free dimming
- ETL certification, Class P
- Protections: Short circuit / Overload / Over Voltage
- Fully isolated aluminum case with IP20 level
- · Suitable for dry or damp location
- Suitable for LED strip, LED modules or LED sign applications etc.

Certificates	ETL			
Protection	Short Current	Hiccup mode,recover automatically affer fault condition is removed		
	Over Loading	≤120%		
	Working TEMP.	-13°F to 113°F		
Environment	Working Humidity	20~90% RH, Non-Condensing		
	Storage TEMP. Humidity	-40~140°F, 10~95% RH		
	Safety Standards	UL8750		
Safety & EMC	Withstand Voltage	I/P-O/P: 1500VAC		
	Isolation Resistance	I/P-O/P: 100M Ω /500VDC/77°F/70% RH		
Notes	All parameters if NOT specially mentioned are measured at 120VAC input, rated load and 77°F of ambient temperature     To extend the driver's using life, please reduce the loading at lower input voltage     Loading should be 5-100%			

Series -	Volt	Current DC -	Watt	Brightness
Constant Voltage	<b>12V</b> 12 Volts <b>24V</b> 24 Volts	Direct Current	20 Watts 60 Watts (12 or 24V) 150 Watts	Dimmable

Specs and model numbers are subject to change with or without notice




## **Constant Voltage Triac Dimmable Transformers**

### Constant Voltage Phase/120-277V Triac dimmable driver Dimming Operation

- The Pulse-Width Modulation (PWM) of output voltage can be adjusted through input terminal of the AC phase line (L) by connection a triac dimmer.
- Usually matching with leading edge/Forward Phase Triac Dimmers (Can customized as a driver only matching trailing edge/reverse phase Triac Dimmers if needed).
- Please try to use dimmers with power at least 2.5 times as the output power of the driver.
- For Forward phase, Magnetic low voltage and Triac Dimmers

### Warning

- Prevent to reverse polarity
- Risk of Fire. Installation Involves special wiring methods to run wiring through a building structure. Consult a qualified electrician
- Risk of Electric Shock. Mount the unit at a height greater than 1 foot from the ground surface.



### Instructions

### **Dimming Operation**

- The Pulse-Width Modulation (PWM) of output voltage can be adjusted through input terminal of the AC phase line (L) by connection a triac dimmer.
- Usually matching with leading edge/Forward Phase Triac Dimmers (Can customized as a driver only matching trailing edge/reverse phase Triac Dimmers if needed).
- Please try to use dimmers with power at least 2.5 times as the output power of the driver.
- For Forward phase, Magnetic low voltage and Triac Dimmers

### Warning

- 1) This driver should be installed by a qualied professional
- 2) Please make sure the transformer is installed with adequate ventilation around it to allow for heat dissipation.
- 3) Ensure that wiring is correct before testing in order to avoid light and power supply damage.