



COMPLIANCE

with IEC EN 61508 and IEC EN 61511

Certificate No.: C-IS-722222940

CERTIFICATE OWNER: OMB Valves S.p.A.
24069 - Cenate Sotto (BG) - Italy

WE HEREWITH CONFIRM THAT
BSE BALL VALVES
MEET THE SIL REQUIREMENTS DETAILED IN THE ANNEXED TABLES
FOR THE SAFETY FUNCTION:

SIF1: "correct switching on demand (open to closed), and tight for closing phase, in low demand mode of operation".

SIF2: "correct switching on demand (closed to open), in low demand mode of operation".

Examination result:

The above reported BSE Ball Valves were found to meet the standard defined requirements of the safety levels detailed in the following table (T-IS-722222940) according to IEC EN 61508, under fulfillment of the conditions listed in the Report R-IS-722222940 Rev.1 dated April, 16th 2020 in its currently valid version, on which this Certificate is based

Examination parameters:

Construction/Functional characteristics and reliability and availability parameters of the above BSE Ball Valves

Official Report No.:

R-IS-722222940 Rev.1

Expiry Date

April, 15th 2023

IT IS TO BE INTENDED THAT THE ABOVE OFFICIAL REPORT AND ITS ANNEXES ARE AN INTEGRAL PART OF THIS DOCUMENT
THE PRESENT DOCUMENT SUBSTITUTES AND REPEALS THE DOCUMENT C-IS-722115592

Reference Standard

IEC EN 61508:2010 Part 2, 4, 6, 7
IEC EN 61511:2016 Part 1, 2, 3

Sesto San Giovanni, April, 16th 2020

TÜV ITALIA Srl

TÜV ITALIA Srl
Industry Service Division
Technical Manager

Paolo Marcone





Italia

SUMMARY TABLE
T-IS-722222940

<i>E/EE/EP safety-related system (final element)</i>	BSE Ball Valves produced by OMB Valves S.p.A.	
<i>Class (size)</i>	Class 1 – NPS ≤ 6”	
<i>System type</i>	Type A	
<i>Systematic Capability</i>	SC3	
<i>Safety Function Definition</i>	<i>SIF1: “Correct switching on demand (open to closed) and tight for closing phase, in low demand mode of operation”</i>	<i>SIF2: “Correct switching on demand (closed to open), in low demand mode of operation”</i>
<i>Max SIL⁽¹⁾</i>	SIL3	SIL3
λ_{TOT}	1,671E-07	1,671E-07
λ_{NE}	7,998E-09	1,269E-07
λ_S	0.000E+00	0.000E+00
$\lambda_{DD,PST}^{(2)}$	8,644E-08	3,446E-08
$\lambda_{DU,FPT}$	7,269E-08	5,806E-09
<i>β and β_D factor</i>	10%	10%
<i>MRT</i>	8 h	8 h
<i>Hardware Safety Integrity</i>	Route 2 _H	Route 2 _H
<i>Systematic Safety Integrity</i>	Route 2 _s	Route 2 _s
Remarks (1) The Safety Integrity Level (SIL) of the entire Safety Instrumented Function (SIF) must be verified via a calculation of PFD _{AVG} considering the redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each subsystem must be checked to assure compliance with the minimum hardware fault tolerance (HFT) requirements. (2) Considering an automatic Partial Stroke Test		

SIL classification according to Standards IEC EN 61508 (Chapters: 2, 4, 6, 7) and IEC EN 61511 (Chapters 1, 2, 3) for BSE Ball Valves produced by OMB Valves S.p.A. – Class 1

T-IS-722222940
NOTE: The present table is integral part of the Document: C-IS-722222940
Date: April, 16th 2020



Italia

SUMMARY TABLE
T-IS-722222940

E/EE/EP safety-related system (final element)	BSE Ball Valves produced by OMB Valves S.p.A.	
Class (size)	Class 2 – NPS > 6”	
System type	Type A	
Systematic Capability	SC3	
Safety Function Definition	SIF1: “Correct switching on demand (open to closed) and tight for closing phase, in low demand mode of operation”	SIF2: “Correct switching on demand (closed to open), in low demand mode of operation”
Max SIL ⁽¹⁾	SIL3	SIL3
λ _{TOT}	3,249E-08	3,249E-08
λ _{NE}	1,660E-09	2,769E-08
λ _S	0.000E+00	0.000E+00
λ _{DD,PST} ⁽²⁾	1,814E-08	3,649E-09
λ _{DU,FPT}	1,269E-08	1,150E-09
β and β _D factor	10%	10%
MRT	8 h	8 h
Hardware Safety Integrity	Route 2 _H	Route 2 _H
Systematic Safety Integrity	Route 2 _s	Route 2 _s
Remarks (1) The Safety Integrity Level (SIL) of the entire Safety Instrumented Function (SIF) must be verified via a calculation of PFD _{AVG} considering the redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each subsystem must be checked to assure compliance with the minimum hardware fault tolerance (HFT) requirements. (2) Considering an automatic Partial Stroke Test		

SIL classification according to Standards IEC EN 61508 (Chapters: 2, 4, 6, 7) and IEC EN 61511 (Chapters 1, 2, 3) for BSE Ball Valves produced by OMB Valves S.p.A. – Class 2

T-IS-722222940
NOTE: The present table is integral part of the Document: C-IS-722222940
Date: April, 16th 2020



COMPLIANCE

with IEC EN 61508 and IEC EN 61511

Certificate No.: C-IS-722264443-01

CERTIFICATE OWNER: OMB Valves S.p.A.
24069 - Cenate Sotto (BG) - Italy

WE HEREWITH CONFIRM THAT
BTE BALL VALVES
MEET THE SIL REQUIREMENTS DETAILED IN THE ANNEXED TABLES
FOR THE SAFETY FUNCTION:

SIF1: "correct switching on demand (open to closed), and tight for closing phase, in low demand mode of operation".

SIF2: "correct switching on demand (closed to open), in low demand mode of operation".

Examination result: The above reported BTE Ball Valves were found to meet the standard defined requirements of the safety levels detailed in the following table (T-IS-722264443-01) according to IEC EN 61508, under fulfillment of the conditions listed in the Report R-IS-722264443-01 Rev.1 dated September, 22nd 2021 in its currently valid version, on which this Certificate is based

Examination parameters: Construction/Functional characteristics and reliability and availability parameters of the above BTE Ball Valves

Official Report No.: R-IS-722264443-01 Rev.1

Expiry Date September, 21st 2024

IT IS TO BE INTENDED THAT THE ABOVE OFFICIAL REPORT AND ITS ANNEXES ARE AN INTEGRAL PART OF THIS DOCUMENT
THE PRESENT DOCUMENT SUBSTITUTES AND REPEALS THE DOCUMENT C-IS-722173138

Reference Standard IEC EN 61508:2010 Part 2, 4, 6, 7
IEC EN 61511:2016 Part 1, 2, 3

Sesto San Giovanni, September, 22nd 2021

TÜV ITALIA Srl

TÜV ITALIA Srl
Industry Service Division
Technical Manager


Paolo Marcone





SUMMARY TABLE

T-IS-722264443-01

E/EE/EP safety-related system (final element)	BTE Ball Valves produced by OMB Valves S.p.A.	
System type	Type A	
Systematic Capability	SC3	
Safety Function Definition	SIF1: “Correct switching on demand (open to closed) and tight for closing phase, in low demand mode of operation”	SIF2: “Correct switching on demand (closed to open), in low demand mode of operation”
Max SIL ⁽¹⁾	SIL3	SIL3
λ _{TOT}	2,078E-07	2,078E-07
λ _{NE}	1,989E-08	1,531E-07
λ _S	0,000E+00	0,000E+00
λ _{DD,PST} ⁽²⁾	1,687E-08	4,025E-08
λ _{DU,FPT}	1,711E-07	1,444E-08
β and β _D factor	10%	10%
MRT	8 h	8 h
Hardware Safety Integrity	Route 2 _H	Route 2 _H
Systematic Safety Integrity	Route 2 _s	Route 2 _s
Remarks (1) The Safety Integrity Level (SIL) of the entire Safety Instrumented Function (SIF) must be verified via a calculation of PFD _{AVG} considering the redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each subsystem must be checked to assure compliance with the minimum hardware fault tolerance (HFT) requirements. (2) Considering an automatic Partial Stroke Test		

SIL classification according to Standards IEC EN 61508 (Chapters: 2, 4, 6, 7) and IEC EN 61511 (Chapters 1, 2, 3) for BTE Ball Valves produced by OMB Valves S.p.A.

T-IS-722264443-01

NOTE: The present table is integral part of the Document: C-IS-722264443-01

Date: September, 22nd 2021



COMPLIANCE

with IEC EN 61508 and IEC EN 61511

Certificate No.: C-IS-722264443-02

CERTIFICATE OWNER: OMB Valves S.p.A.
24069 - Cenate Sotto (BG) - Italy

WE HEREWITH CONFIRM THAT
TRIPLE OFFSET BUTTERFLY VALVES (TOBV)
MEET THE SIL REQUIREMENTS DETAILED IN THE ANNEXED TABLES
FOR THE SAFETY FUNCTION:

SIF1: "correct switching on demand (open to closed), and tight for closing phase, in low demand mode of operation".

SIF2: "correct switching on demand (closed to open), in low demand mode of operation".

Examination result: The above reported Triple Offset Butterfly Valves were found to meet the standard defined requirements of the safety levels detailed in the following table (T-IS-722264443-02) according to IEC EN 61508, under fulfillment of the conditions listed in the Report R-IS-722264443-02 Rev.1 dated September, 22nd 2021 in its currently valid version, on which this Certificate is based

Examination parameters: Construction/Functional characteristics and reliability and availability parameters of the above Triple Offset Butterfly Valves

Official Report No.: R-IS-722264443-02 Rev.1

Expiry Date September, 21st 2024

IT IS TO BE INTENDED THAT THE ABOVE OFFICIAL REPORT AND ITS ANNEXES ARE AN
INTEGRAL PART OF THIS DOCUMENT
THE PRESENT DOCUMENT SUBSTITUTES AND REPEALS THE DOCUMENT C-IS-722172951

Reference Standard IEC EN 61508:2010 Part 2, 4, 6, 7
IEC EN 61511:2016 Part 1, 2, 3

Sesto San Giovanni, September, 22nd 2021

TÜV ITALIA Srl



TÜV ITALIA Srl
Industry Service Division
Technical Manager

Paolo Marcone
Paolo Marcone



SUMMARY TABLE
T-IS-722264443-02

E/EE/EP safety-related system (final element)	Triple Offset Butterfly Valves produced by OMB Valves S.p.A.	
System type	Type A	
Systematic Capability	SC3	
Safety Function Definition	SIF1: “Correct switching on demand (open to closed) and tight for closing phase, in low demand mode of operation”	SIF2: “Correct switching on demand (closed to open), in low demand mode of operation”
Max SIL ⁽¹⁾	SIL3	SIL3
λ _{TOT}	4,436E-07	4,436E-07
λ _{NE}	4,246E-08	3,269E-07
λ _S	0,000E+00	0,000E+00
λ _{DD,PST} ⁽²⁾	3,600E-08	8,591E-08
λ _{DU,FPT}	3,651E-07	3,082E-08
β and β _D factor	10%	10%
MRT	8 h	8 h
Hardware Safety Integrity	Route 2 _H	Route 2 _H
Systematic Safety Integrity	Route 2 _s	Route 2 _s
Remarks (1) The Safety Integrity Level (SIL) of the entire Safety Instrumented Function (SIF) must be verified via a calculation of PFD _{AVG} considering the redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each subsystem must be checked to assure compliance with the minimum hardware fault tolerance (HFT) requirements. (2) Considering an automatic Partial Stroke Test		

SIL classification according to Standards IEC EN 61508 (Chapters: 2, 4, 6, 7) and IEC EN 61511 (Chapters 1, 2, 3) for Triple Offset Butterfly Valves produced by OMB Valves S.p.A.

T-IS-722264443-02
NOTE: The present table is integral part of the Document: C-IS-722264443-02
Date: September, 22nd 2021