

## EQUIVALENT SOUNDABSORPTION AREA PER OBJECT conform EN-ISO 354:2003




Principal: Buzzispace

Variant 1A: BuzziFold, 2 elements measured on blocks 500 mm high



— 1/3 oct.  
\* 1/1 oct.



volume reverberation room: 214 m<sup>3</sup>

number of elements: 2

measured at: Peutz Laboratory for Acoustics

signal: broad-band noise

bandwidth: 1/3 octave

	0,32	0,81	0,99	1,48	1,90	2,25
1/3 oct.	0,27	1,07	1,23	1,68	2,01	2,44
	0,68	1,01	1,46	1,79	2,12	2,66
<b>1/1 oct.</b>	<b>0,42</b>	<b>0,96</b>	<b>1,23</b>	<b>1,65</b>	<b>2,01</b>	<b>2,45</b>

publication is permitted for the entire page only

Mook, measured at 13-10-2022