

EQUIVALENT SOUNDABSORPTION AREA PER OBJECT conform ISO 354:2003




principal: BuzziSpace

#5; BuzziK



— 1/3 oct.  
\* 1/1 oct.



Absorb, versie 5.9 mode 9, PM: RA, file: a4183 Eh:1-36 F#:324-359 A#:360 T<sub>1</sub> = 17,1 °C T<sub>2</sub> = 17,5 °C p<sub>1</sub> = 102,2 kPa p<sub>2</sub> = 102,2 kPa h<sub>1</sub> = 51,9 % h<sub>2</sub> = 51,3 %

volume reverberation room: 214 m<sup>3</sup>

number of elements: 1

measured at: Peutz Laboratory for Acoustics

signal: broad-band noise

bandwidth: 1/3 octave

publication is permitted for the entire page only

1/3 oct.	0,21	1,03	1,19	1,27	1,39	1,47
	0,47	0,92	1,37	1,18	1,41	1,48
	0,86	0,95	1,10	1,47	1,48	1,69
				Mook, measured at 15-03-2022		