

EQUIVALENT SOUNDABSORPTION AREA PER OBJECT conform ISO 354:2003




principal: BuzziSpace

Variant 6: BuzziHook



— 1/3 oct.
* 1/1 oct.



	1,44	2,32	3,94	5,74	7,96	8,83
1/3 oct.	1,51	2,88	4,58	6,66	8,14	8,28
	1,69	3,29	5,01	7,25	8,42	7,91
1/1 oct.	1,55	2,83	4,51	6,55	8,17	8,34

Absorb, versie 5.9 mode 9, PM: MH, file: a3898 E#:1-36 F#:2222-257 A#:258 T₁ = 20,6 °C T₂ = 20,8 °C p₁ = 101,6 kPa p₂ = 101,7 kPa h₁ = 57,5 % h₂ = 51,6 %

volume reverberation room: 214 m³

number of elements during tests: 2

measured at: Peutz Laboratory for Acoustics

signal: broad-band noise

bandwidth: 1/3 octave

publication is permitted for the entire page only

Mook, measured at 29-07-2020