

EQUIVALENT SOUNDABSORPTION AREA PER OBJECT conform ISO 354:2003




principal: BuzziSpace

#1; Buzzi Tripl Cockpit



— 1/3 oct.
* 1/1 oct.



	0,18	0,59	1,07	1,33	1,80	2,07
1/3 oct.	0,40	0,74	1,07	1,38	1,97	2,06
	0,73	0,87	1,21	1,65	1,99	2,13
1/1 oct.	0,44	0,73	1,12	1,45	1,92	2,09

Absorb, versie 5.9 mode 9, PM: RA, file: a4183 Eh:1-36 F#:37-72 A#:73 T₁ = 17,1 °C T₂ = 17,4 °C p₁ = 102,2 kPa p₂ = 102,2 kPa h₁ = 51,9 % h₂ = 51,6 %

volume reverberation room: 214 m³

number of elements: 2

measured at: Peutz Laboratory for Acoustics

signal: broad-band noise

bandwidth: 1/3 octave

publication is permitted for the entire page only

Mook, measured at 15-03-2022

report A 4183-2E-RA

figure 3