


EQUIVALENT SOUNDABSORPTION AREA PER OBJECT conform EN-ISO 354:2003




Principal: Buzzispace

Variant 4: BuzziShield Free Arc



— 1/3 oct.
* 1/1 oct.



volume reverberation room: 214 m³

number of elements: 2

measured at: Peutz Laboratory for Acoustics

signal: broad-band noise

bandwidth: 1/3 octave

	0,71	1,17	2,12	3,47	4,50	4,58
1/3 oct.	0,55	1,53	2,48	3,75	4,65	4,36
	0,84	1,69	2,94	4,20	4,69	4,13
1/1 oct.	0,70	1,46	2,51	3,81	4,61	4,36

publication is permitted for the entire page only

Mook, measured at 13-10-2022