


## EQUIVALENT SOUNDABSORPTION AREA PER OBJECT conform EN-ISO 354:2003



principal: BuzziSpace

#7; BuzziPebl Two Medium, on 50 cm



Absorb, versie 5.10.1 mode 9, PM:JK, file: a4435 E#:1-36 F#:261-296 A#:297 T<sub>1</sub>=21,2 °C T<sub>2</sub>=21,2 °C p<sub>1</sub>=101,6 kPa p<sub>2</sub>=101,7 kPa h<sub>1</sub>=66,7 % h<sub>2</sub>=64,1 %

volume reverberation room: 214 m<sup>3</sup>


number of objects measured: 4

measured at: Peutz Laboratory for Acoustics

signal: broad-band noise

bandwidth: 1/3 octave

- 1/3 oct.
- \* 1/1 oct.



	0,15	0,26	0,50	0,64	0,68	0,71
1/3 oct.	0,13	0,34	0,62	0,63	0,67	0,70
	0,19	0,46	0,60	0,67	0,73	0,78
1/1 oct.	<b>0,16</b>	<b>0,35</b>	<b>0,57</b>	<b>0,65</b>	<b>0,69</b>	<b>0,73</b>

RA

publication is permitted for the entire page only

Mook, measured at 17-08-2023