


EQUIVALENT SOUNDABSORPTION AREA PER OBJECT conform EN-ISO 354:2003



principal: BuzziSpace

#2; BuzziPebl One Large, on 50 cm



Absorb, versie 5.10.1 mode 9, PM:JK, file: a4435 E#:1-36 F#:74-109 AH:110 T₁ = 21,2 °C T₂ = 21,2 °C p₁ = 101,6 kPa p₂ = 101,7 kPa h₁ = 66,7 % h₂ = 64,7 %

volume reverberation room: 214 m³


number of objects measured: 5

measured at: Peutz Laboratory for Acoustics

signal: broad-band noise

bandwidth: 1/3 octave

- 1/3 oct.
- * 1/1 oct.



	0,27	0,86	1,45	1,72	1,80	1,75
1/3 oct.	0,47	1,03	1,55	1,71	1,74	1,73
	0,61	1,21	1,64	1,71	1,78	1,76
1/1 oct.	0,45	1,03	1,55	1,71	1,77	1,75

RA

publication is permitted for the entire page only

Mook, measured at 17-08-2023