

## EQUIVALENT SOUNDABSORPTION AREA PER OBJECT conform EN-ISO 354:2003



principal: BuzziSpace

#1; BuzziPebl One Large, directly on floor



Absorb, versie 5.10.1 mode 9, PM:RA, file: a4435 E#:1-36 F#:37-72 A#:73 T<sub>1</sub> = 21,2 °C T<sub>2</sub> = 21,1 °C p<sub>1</sub> = 101,6 kPa p<sub>2</sub> = 101,7 kPa h<sub>1</sub> = 66,7 % h<sub>2</sub> = 65,7 %

volume reverberation room: 214 m<sup>3</sup>


number of objects measured: 5

measured at: Peutz Laboratory for Acoustics

signal: broad-band noise

bandwidth: 1/3 octave

— 1/3 oct.  
\* 1/1 oct.



	0,19	0,77	1,33	1,41	1,45	1,38
1/3 oct.	0,41	1,15	1,40	1,41	1,45	1,38
	0,51	1,37	1,38	1,42	1,44	1,39
1/1 oct.	<b>0,37</b>	<b>1,10</b>	<b>1,37</b>	<b>1,41</b>	<b>1,45</b>	<b>1,38</b>

RA

publication is permitted for the entire page only

Mook, measured at 17-08-2023