

EQUIVALENT SOUNDABSORPTION AREA PER OBJECT conform EN-ISO 354:2003



principal: BuzziSpace

#14; BuzziJet Square Medium, on 50 cm



Absorb, versie 5.10.1 mode 9, PM:JK, file: a4435 E#:1-36 F#:520-555 A#:556 T₁=21,2 °C T₂=21,1 °C p₁=101,6 kPa p₂=101,7 kPa h₁=66,7 % h₂=64,8 %

volume reverberation room: 214 m³


number of objects measured: 2

measured at: Peutz Laboratory for Acoustics

signal: broad-band noise

bandwidth: 1/3 octave

— 1/3 oct.
* 1/1 oct.



	0,46	0,87	1,35	1,98	2,04	1,87
1/3 oct.	0,62	1,05	1,59	2,03	1,89	1,94
	0,50	1,25	1,75	2,00	1,99	1,94
1/1 oct.	0,53	1,06	1,56	2,00	1,97	1,92

RA

publication is permitted for the entire page only

Mook, measured at 17-08-2023