


EQUIVALENT SOUNDABSORPTION AREA PER OBJECT conform EN-ISO 354:2003




Principal: Buzzispace

Variant 3B: BuzziPleat Edel Long Medium, 2 elements measured on the laboratory floor



— 1/3 oct.
* 1/1 oct.



volume reverberation room: 214 m³

number of elements: 2

measured at: Peutz Laboratory for Acoustics

signal: broad-band noise

bandwidth: 1/3 octave

	0,16	0,26	1,36	2,16	2,02	2,04
1/3 oct.	0,06	0,56	1,90	2,20	1,94	2,01
	0,32	0,92	2,05	2,09	2,03	1,99
1/1 oct.	0,18	0,58	1,77	2,15	2,00	2,01