


EQUIVALENT SOUNDABSORPTION AREA PER OBJECT conform EN-ISO 354:2003


Principal: Buzzispace



Variant 3A: BuzziPleat Edel Long Medium, 2 elements measured on blocks 500 mm high



— 1/3 oct.
* 1/1 oct.



	0,43	0,87	1,02	2,18	2,78	2,82
1/3 oct.	0,42	0,89	1,61	2,57	2,77	2,95
	0,90	0,86	1,84	2,70	2,84	2,99
1/1 oct.	0,58	0,87	1,49	2,48	2,80	2,92

publication is permitted for the entire page only

Mook, measured at 13-10-2022

Absorb, versie 5.9 / 5.10.1 mode 9, PM: JK, file: a4183 E#373-408 F#520-555 A#556 T₁ = 17,2 °C T₂ = 17,1 °C p₁ = 101,4 kPa p₂ = 101,4 kPa h₁ = 55,9 % h₂ = 58,5 %

volume reverberation room: 214 m³

number of elements: 2

measured at: Peutz Laboratory for Acoustics

signal: broad-band noise

bandwidth: 1/3 octave