

EQUIVALENT SOUNDABSORPTION AREA PER OBJECT conform EN-ISO 354:2003

principal: BuzziSpace



#10; BuzziPleat Ripple Medium, on 50 cm



volume reverberation room: 214 m<sup>3</sup>


number of objects measured: 2

measured at: Peutz Laboratory for Acoustics

signal: broad-band noise

bandwidth: 1/3 octave

— 1/3 oct.  
\* 1/1 oct.



|          |      |      |      |      |      |      |
|----------|------|------|------|------|------|------|
|          | 0,16 | 0,35 | 0,69 | 1,15 | 1,38 | 1,47 |
| 1/3 oct. | 0,21 | 0,50 | 0,89 | 1,17 | 1,39 | 1,55 |
|          | 0,26 | 0,59 | 1,04 | 1,25 | 1,51 | 1,68 |
| 1/1 oct. | 0,21 | 0,48 | 0,87 | 1,19 | 1,43 | 1,57 |

RA

publication is permitted for the entire page only

Mook, measured at 17-08-2023