


EQUIVALENT SOUNDABSORPTION AREA PER OBJECT conform EN-ISO 354:2003

principal: BuzziSpace



#11; BuzziPleat Ripple Large, on 50 cm



volume reverberation room: 214 m³

number of objects measured: 2

measured at: Peutz Laboratory for Acoustics

signal: broad-band noise

bandwidth: 1/3 octave

	0,32	1,26	2,26	2,69	3,10	3,43
1/3 oct.	0,51	1,49	2,42	2,77	3,24	3,47
	0,71	1,70	2,54	2,89	3,31	3,51
1/1 oct.	0,51	1,48	2,41	2,78	3,22	3,47

RA