

EQUIVALENT SOUND ABSORPTION AREA PER OBJECT conform EN-ISO 354:2003



principal: BuzziSpace

#2; BuzziShroom



Absorb, versie 5.10.2 mode 9, PM: JK, file: a4539 E#:1-36 F#:74-109 A#:110 T₁ = 15,8 °C T₂ = 16,0 °C p₁ = 101,4 kPa p₂ = 101,4 kPa h₁ = 56,7 % h₂ = 57,4 %


volume reverberation room
214 m³

number of elements measured
2

measured at
Peutz Laboratory for Acoustics

signal
broad-band noise

bandwidth
1/3 octave



	125	250	500	1k	2k	4k
1/3 oct.	1,47	2,71	3,30	3,44	3,47	3,33
	2,13	3,12	3,33	3,43	3,38	3,39
1/1 oct.	1,71	2,76	3,28	3,43	3,46	3,36

— 1/3 oct.
* 1/1 oct.

publication is permitted for the entire page only

RA

Mook, measured at 19-03-2024