

## EQUIVALENT SOUNDABSORPTION AREA PER OBJECT conform EN-ISO 354:2003



principal: BuzziSpace

#4b; BuzziRe Desk



Absorb, versie 5.10.2 mode 9, PM: JK, file: a4539 E#:1-36 F#:185-220 A#:221 T<sub>1</sub> = 15,8 °C T<sub>2</sub> = 16,0 °C p<sub>1</sub> = 101,4 kPa p<sub>2</sub> = 101,4 kPa h<sub>1</sub> = 56,7 % h<sub>2</sub> = 58,1 %


volume reverberation room  
214 m<sup>3</sup>

number of elements measured  
2

measured at  
Peutz Laboratory for Acoustics

signal  
broad-band noise

bandwidth  
1/3 octave



— 1/3 oct.  
\* 1/1 oct.

	125	250	500	1k	2k	4k
1/3 oct.	0,08	0,46	0,47	0,78	1,33	1,56
	0,25	0,36	0,55	0,93	1,52	1,62
	0,32	0,54	0,62	1,10	1,48	1,58
<b>1/1 oct.</b>	<b>0,22</b>	<b>0,45</b>	<b>0,55</b>	<b>0,94</b>	<b>1,44</b>	<b>1,59</b>

publication is permitted for the entire page only

*RA*

Mook, measured at 19-03-2024