

EQUIVALENT SOUND ABSORPTION AREA PER OBJECT conform EN-ISO 354:2003



principal: BuzziSpace

#7; BuzziPlanter 90 Half



Absorb, versie 5.10.2 mode 9, PM: JK, file: a4539 E#:1-36 F#:296-331 A#:332 T₁ = 15,8 °C T₂ = 16,5 °C p₁ = 101,4 kPa p₂ = 101,4 kPa h₁ = 56,7 % h₂ = 57,9 %


volume reverberation room
214 m³

number of elements measured
2

measured at
Peutz Laboratory for Acoustics

signal
broad-band noise

bandwidth
1/3 octave



	125	250	500	1k	2k	4k
1/3 oct.	0,64	1,62	1,49	1,47	1,44	1,40
	0,97	1,81	1,29	1,38	1,38	1,45
	1,48	1,73	1,32	1,37	1,39	1,31
1/1 oct.	1,03	1,72	1,37	1,41	1,40	1,39

publication is permitted for the entire page only

RA

Mook, measured at 19-03-2024