


EQUIVALENT SOUNDABSORPTION AREA PER OBJECT ACCORDING EN-ISO 354:2003

principal: BuzziSpace



#1; BuzziChicle Light Round



volume reverberation room
214 m³

number of elements during measurements
3

measured at
Peutz Laboratory for Acoustics

signal
broad-band noise

bandwidth
1/3 octave

— 1/3 oct.
* 1/1 oct.

	0,2	0,5	1,0	1,3	1,4	1,4
1/3 oct.	0,3	0,7	1,2	1,4	1,4	1,4
	0,4	0,9	1,3	1,4	1,4	1,4
1/1 oct.	0,3	0,7	1,2	1,4	1,4	1,4

publication is permitted for the entire page only

RA

Molenhoek, measured at 04-09-2025