



EQUIVALENT SOUNDABSORPTION AREA PER OBJECT ACCORDING EN-ISO 354:2003



principal: BuzziSpace

#2; BuzziChicle Light Rectangular



volume reverberation room
214 m³

number of elements during measurements
2

measured at
Peutz Laboratory for Acoustics

signal
broad-band noise

bandwidth
1/3 octave

— 1/3 oct.
* 1/1 oct.

	0,3	0,6	1,2	1,8	1,8	1,9	
1/3 oct.	0,3	0,8	1,4	1,7	1,8	2,0	m ²
	0,2	1,3	1,6	1,8	1,9	1,9	
1/1 oct.	0,3	0,9	1,4	1,8	1,8	1,9	m ²

publication is permitted for the entire page only

RA

Molenhoek, measured at 04-09-2025