


EQUIVALENT SOUNDABSORPTION AREA PER OBJECT ACCORDING EN-ISO 354:2003

principal: BuzziSpace



#3; BuzziChicle Planter Round



volume reverberation room
214 m³

number of elements during measurements
2

measured at
Peutz Laboratory for Acoustics

signal
broad-band noise

bandwidth
1/3 octave

	0,5	0,8	0,9	1,3	1,3	1,3	
1/3 oct.	0,4	0,9	1,2	1,4	1,3	1,3	m ²
	0,6	1,0	1,1	1,3	1,4	1,4	
1/1 oct.	0,5	0,9	1,1	1,3	1,3	1,3	m ²

— 1/3 oct.
* 1/1 oct.

publication is permitted for the entire page only

RA

Molenhoek, measured at 04-09-2025