


EQUIVALENT SOUNDABSORPTION AREA PER OBJECT ACCORDING EN-ISO 354:2003

principal: BuzziSpace



#4; BuzziChicle Planter Rectangular



volume reverberation room
214 m³

number of elements during measurements
2

measured at
Peutz Laboratory for Acoustics

signal
broad-band noise

bandwidth
1/3 octave

	1,1	1,4	1,6	2,0	2,0	1,9
1/3 oct.	0,8	1,6	1,7	2,0	2,0	2,0
	0,9	1,6	1,8	2,1	2,0	1,9
1/1 oct.	1,0	1,5	1,7	2,0	2,0	2,0

— 1/3 oct.
* 1/1 oct.

publication is permitted for the entire page only

RA

Molenhoek, measured at 04-09-2025